

(TO BE SUBSTITUTED BEARING SAME NUMBER AND DATE)

GOVERNMENT OF PUNJAB
DEPARTMENT OF NEW AND RENEWABLE ENERGY SOURCES
(ENERGY BRANCH)

ORDER

In supersession of the Department of New and Renewable Energy Sources, Government of Punjab, Notification No. 18/6/13-PE1/791 dated the 19th March, 2015, in exercise of the powers conferred under section 18 of the Energy Conservation Act, 2001 (Central Act no. 52 of 2001), the Governor of Punjab is pleased to issue the following directions for efficient use of energy and its conservation, namely:-

- (i) The use of minimum BEE 2 Star labeled and ISI marked, oil immersed, naturally cooled, three phase and non-sealed type out door distribution transformers by the State Utilities or by any other stake holder as per the latest Government of India, Ministry of Power, Notification No. S.O. 4062(E) dated the 16th December, 2016; and
- (ii) The standard ratings of distribution transformers covered under the BEE star labeling program are 16 KVA to 200 KVA as per Table 2, and 250 KVA to 2500 KVA as per Table 3 of the said notification.

This notification shall come into force for future procurement with immediate effect.

Dated : Chandigarh
the 17th January, 2018


ANIRUDH TEWARI, IAS
Principal Secretary to Govt. of Punjab
Department of New & Renewable Energy Sources

Endst. No. 18/6/2013-PE1/ 300-306

Dated; Chandigarh: 24.01.2018

A copy of the above is forwarded to the following for information and necessary action:-

- 1) All Heads of Department in the State.
- 2) Chairperson, Punjab State Electricity Regulatory Authority, SCO No. 220-221, Sector 34, Chandigarh.
- 3) All commissioners of Divisions and Deputy Commissioners in the State.
- 4) Chairman-cum-Managing Director, Punjab State Power Corporation Limited, The Mall, Patiala.
- 5) All Executive Directors and Managing Directors of the Board/Corporations in the State.
- 6) Chief Executive, Punjab Energy Development Agency, Chandigarh.
- 7) Chief Electrical Inspector, Punjab.


R.K.Kaushik
Special Secretary